

Post Oak SUD

107 NE 2nd Street

Hubbard, TX 76648

254-576-1012

CCR 2024

Dear Post Oak Customer,

The Texas Commission on Environmental Quality (TCEQ) requires Post Oak SUD to annually transmit drinking water quality data to all customers prior to June, 1 2025. The enclosed 2024 Post Oak water quality data (chemical analysis results) is provided for the purpose of preparing and distributing the annual Drinking Water Data Report (Consumer Confidence Report) to your customers.

Please feel free to contact Post Oak at (254) 576-1012 should you have any comments or questions.

Sincerely,



Robert Mathis, Mgr. – Post Oak SUD

Enclosed (12 pgs.)

Consumer Confidence Report
Provider Certification of Delivery

Texas Commission on Environmental Quality

PWS ID Number: 1090030 PWS Name: POST OAK SUD

☒ I certify, that as a representative of the public water system named above, our water system has distributed the appropriate drinking water quality data to the community water system(s) (receiver) we provided water to in 2020 as described in 30 TAC §290.274(g) by April 1, 2021. This will ensure that they can create and deliver their annual Consumer Confidence Report to their customers.

Date of Delivery to receiver(s): 4-27-2025

☐ I certify, that as a representative of the public water system named above, that this system did not provide water to another system by any means in the previous calendar year.

Please confirm list of systems your water system is interconnected to in Drinking Water Watch. If any updates are needed, please contact PWSINVEN@tceq.texas.gov

Certified By:

Name (print): Robert Mathis

Title: Manager

Phone Number: (254) 855-5655

Signature: Robert Mathis

Date: 4-26-2025

All systems are required to mail or email by May 1 the Certificate of Delivery to:

<p>If submitting by certified mail:</p> <p>TCEQ DWSF Section - MC 155, Attn CCR 12100 Park 35 Circle Austin, Texas 78753</p>	<p>If submitting by regular mail:</p> <p>TCEQ DWSF Section - MC 155, Attn CCR PO BOX 13087 Austin, TX 78711-3087</p>
<p>If submitting by email: PWSCCR@tceq.texas.gov</p>	



Texas Commission on Environmental Quality

Consumer Confidence Report Certificate of Delivery

PWS Name: Post Oak SUD PWS ID: 1090030

Date of Distribution: April 1, 2025 Population Served: _____

Complete each section:

Report Year: 2025

Direct Delivery - Check the applicable statement.

- ☐ The CCR was delivered in physical form or electronically to all customers.
Direct link to CCR: _____
- ☐ Our system serves fewer than 500 people, and a notice that the CCR is available upon request was provided to all customers.

Good Faith Delivery - Check at least one method.

- ☒ Posted the CCR online
- ☐ Mailed the CCR to people who receive mail, but who do not receive bills
- ☐ Advertised the availability of the CCR in news media
- ☐ Posted the CCR in public places
- ☐ Delivered multiple copies to single billing addresses serving multiple persons
- ☐ Delivered multiple copies of the CCR to community organizations
- ☐ Other: _____

Public Notice - Check if applicable.

- ☐ I have included or attached additional mandatory language to satisfy public notice requirements due to drinking water violations.

Wholesale Providers - Check one if applicable.

- ☒ Our water system distributed the appropriate drinking water quality data to the receiving water systems by April 1 as described in 30 TAC 290.274(g).
- ☐ Our water system did not provide water by any means to connected active water systems.

I certify the above referenced water system has distributed the consumer confidence report identified above, and that the information in the notice is correct and consistent, in accordance with applicable regulations under Title 30 of the Texas Administrative Code, Chapter 290 and/or Title 40 of the Code of Federal Regulations, Chapter 141.

Certified by (print name): Robert Mathis Title: Manager

Signature: Robert Mathis Date: April 1, 2025

Email: Robmathisjr@hotmail.com Hubbard post oak@yahoo.com

Deliver this completed and signed form along with a representative copy of the Consumer Confidence Report using one of the following methods:

Email (recommended)	Certified Mail	Regular Mail
PWSCCR@tceq.texas.gov	TCEQ DWSF, MC-155, Attn: CCR 12100 Park 35 Circle Austin, TX 78753	TCEQ DWSF, MC-155, Attn: CCR PO Box 13087 Austin, TX 78711-3087

Instructions for completing Consumer Confidence Reports are available online at:
<https://www.tceq.texas.gov/drinkingwater/ccr>

2022 Consumer Confidence Report for Public Water System CITY OF CORSICANA

This is your water quality report for January 1 to December 31, 2022

For more information regarding this report contact:

CITY OF CORSICANA provides surface water from **Navarro Mills Lake, Richland Chambers Reservoir, and Lake Halbert** located in **Navarro County**.

Name Jason Beard, Environmental Services Director

Phone 903-654-4889

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (903) 654 - 4889.

Definitions and Abbreviations

Definitions and Abbreviations

Action Level:

The following tables contain scientific terms and measures, some of which may require explanation.

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Avg:

Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment:

A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment:

A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or whv total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or MCL:

The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or MCLG:

The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL:

The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG:

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

MFL

million fibers per liter (a measure of asbestos)

mrem:

millirems per year (a measure of radiation absorbed by the body)

na:

not applicable.

NTU

nephelometric turbidity units (a measure of turbidity)

pCi/L

picocuries per liter (a measure of radioactivity)

Definitions and Abbreviations

ppb:

micrograms per liter or parts per billion

ppm:

milligrams per liter or parts per million

ppq

parts per quadrillion, or picograms per liter (pg/L)

ppt

parts per trillion, or nanograms per liter (ng/L)

Treatment Technique or TT:

A required process intended to reduce the level of a contaminant in drinking water.

Information about your Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Information about Source Water

TCEQ completed an assessment of your source water, and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants will be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact **Jason Beard** at **903-654-4889**

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	2022	1.3	1.3	0.05	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	2022	0	15	5.7	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

Variances or Exemptions

Variance or Exemptions	Explanation of Variance	Date Variance was issued	Date Variance Expires	Brief status on the steps the System is taking to comply with the terms and Schedule of the Variance.	Any opportunity for public input on the review or removal of the Variance.
Variance Alternative Capacity Requirement (ACR)	ACR is a reduction in the TCEQ's .6gpm/connection Rule	6/1/2010	N/A	The City is monitoring water pumpage so not to exceed variance requirements	Not at this time.

Coliform Bacteria

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E. Coli Maximum Contaminant Level	Total No. of Positive E. Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 positive monthly sample.	0	TT	0	N	Naturally present in the environment.

2022 Water Quality Test Results

Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Halooacetic Acids (HAA5)	2022	20	10.9 - 22.5	No goal for the total	60	ppb	N	By-product of drinking water disinfection.

*The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year

Total Trihalomethanes (TTHM)	2022	50	32.2 - 63.3	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
------------------------------	------	----	-------------	-----------------------	----	-----	---	--

*The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Aluminum	2022	0.029	0.023 – 0.029	0.2	0.2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.

Barium	2022	0.059	0.047 - 0.059	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Cyanide	2022	121	92.8 - 121	200	200	ppb	N	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories.
Fluoride	2022	0.554	0.498 - 0.554	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2022	0.181	0.0882 - 0.181	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	07/26/2017	1.5	1.5 - 1.5	0	5	pCi/L	N	Erosion of natural deposits.

Synthetic organic contaminants including pesticides and herbicides	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Atrazine	2022	1.2	0.2 - 1.2	3	3	ppb	N	Runoff from herbicide used on row crops.

Disinfectant Residual

A blank disinfectant residual table has been added to the CCR template, you will need to add data to the fields. Your data can be taken off the Disinfectant Level Quarterly Operating Reports (DLQOR).

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Source in Drinking Water
Chloramines	2022	2.07	0.5 – 3.4	4	4	ppm	N	Water additive used to control microbes.

	Level Detected	Limit (Treatment Technique)	Violation	Likely Source of Contamination
Highest single measurement	0.17 NTU	1 NTU	N	Soil runoff.
Lowest monthly % meeting limit	100%	0.3 NTU	N	Soil runoff.

Information Statement: Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration system and disinfectants.

Total Organic Carbon

The percentage of Total Organic Carbon (TOC) removal was measured each month and the system met all TOC removal requirements set, unless a TOC violation is noted in the violations section.

In the water loss audit submitted to the Texas Water Development Board for the time period of Jan-Dec 2022, our system lost an estimated 163,376,084 gallons of water. If you have any questions about the water loss audit please call the PWS phone number listed at the beginning of this report.

Average Chlorine Residual
2024

Month	Average Residual (mg/L)
January	2.64
February	2.46
March	2.48
April	2.43
May	2.26
June	2.04
July	1.99
August	2.10
September	2.25
October	2.27
November	2.20
December	2.27
2024 Yearly Average	2.28 mg/L

Min reading 0.6 mg/L
Max Reading 3.8 mg/L

Detected Regulated Contaminates for 2024

EP2 Lake Halbert

SOC Pesticide	Detected Quantity	MCL	Date Collected	Analytical Method
Atrazine	<0.1 ug/L	3 ug/L	1/31/2024	E525.2 GC/MS
Metolachlor	<0.1 ug/L	N/A	1/31/2024	E525.2 GC/MS
VOC's	Detected Quantity	MCL	Date Collected	Analytical Method
Acetone	<5.00 ug/L	N/A	8/12/2024	E524.2 GC/MS
Chloroform	25.5 ug/L	N/A	8/12/2024	E524.2 GC/MS
Bromodichloromethane	16.2 ug/L	N/A	8/12/2024	E524.2 GC/MS
Dibromochloromethane	4.82 ug/L	N/A	8/12/2024	E524.2 GC/MS

Inorganics

Chloride	19.1 mg/L	300.0 mg/L	1/31/2024	E300.0 Anions
Fluoride	0.481 mg/L	4.0 mg/L	1/31/2024	E300.0 Anions
Nitrate (as N)	0.200 mg/L	10.0 mg/L	1/31/2024	E300.0 Anions
Sulfate	95.6 mg/L	300.0 mg/L	1/31/2024	E300.0 Anions
Total Dissolved Solids	250 mg/L	1000.0 mg/L	1/31/2024	SM2540C

Inorganics

Metals Trace Elements

Calcium Total	44.9 mg/L	N/A	1/31/2024	E200.7 Metals, Trace
Potassium Total	5.36 mg/L	N/A	1/31/2024	E200.7 Metals, Trace
Magnesium Total	7.00 mg/L	N/A	1/31/2024	E200.7 Metals, Trace
Sodium Total	29.9 mg/L	N/A	1/31/2024	E200.7 Metals, Trace

E200.8 ICP-MS

Aluminum Total	0.035 mg/L	0.2 mg/L	1/31/2024	E200.8 IC-MS
Barium Total	0.057 mg/L	2.0 mg/L	1/31/2024	E200.8 IC-MS
Chromium Total	<0.00100 mg/L	0.10 mg/L	1/31/2024	E200.8 IC-MS
Copper Total	0.0013 mg/L	1.0 mg/L	1/31/2024	E200.8 IC-MS
Manganese Total	0.0025 mg/L	0.05 mg/L	1/31/2024	E200.8 IC-MS
Nickel Total	<0.00100 mg/L	0.1 mg/L	1/31/2024	E200.8 IC-MS

DEFINITIONS

ug/l parts per billion or micrograms per liter
mg/l parts per million or milligrams per liter
Only contaminants at detectable level reported

Detected Regulated Contaminates for 2024

EP 1 Navarro Mills

SOC Pesticide	Detected Quantity	MCL	Date Collected	Analytical Method
Atrazine	0.3 ug/L	3 ug/L	1/31/2024	E525.2 GC/MS
Metolachlor	<0.1 ug/L	N/A	1/31/2024	E525.2 GC/MS
VOC's				
Acetone	<5.00 ug/L	N/A	8/12/2024	E524.2 GC/MS
Chloroform	40.6 ug/L	N/A	8/12/2024	E524.2 GC/MS
Bromodichloromethane	17.3 ug/L	N/A	8/12/2024	E524.2 GC/MS
Dibromochloromethane	4.10 ug/L	N/A	8/12/2024	E524.2 GC/MS
Inorganics				
Chloride	14.4 mg/L	300.0 mg/l	1/31/2024	E300.0 Anions
Fluoride	0.496 mg/L	4.0 mg/l	1/31/2024	E300.0 Anions
Nitrate (as N)	1.38 mg/L	10.0 mg/l	1/31/2024	E300.0 Anions
Sulfate	54.4 mg/L	300.0 mg/l	1/31/2024	E300.0 Anions
Total Dissolved Solids	202 mg/L	1000.0 mg/l	1/31/2024	SM2540C
Inorganics				
Metals Trace Elements				
Calcium	42.4 mg/L	N/A	1/31/2024	E200.7 Metals, Trace
Magnesium	3.16 mg/L	N/A	1/31/2024	E200.7 Metals, Trace
Potassium	4.68 mg/L	N/A	1/31/2024	E200.7 Metals, Trace
Sodium Total	24.0 mg/L	N/A	1/31/2024	E200.7 Metals, Trace
E200.8 ICP-MS				
Aluminum Total	0.028 mg/L	0.2 mg/l	1/31/2024	E200.8 IC-MS
Barium Total	0.044 mg/L	2.0 mg/l	1/31/2024	E200.8 IC-MS
Chromium	<0.00100 mg/L	0.10 mg/l AL	1/31/2024	E200.8 IC-MS
Copper Total	0.0036 mg/L	1.0 mg/l AL	1/31/2024	E200.8 IC-MS
Manganese Total	0.0035 mg/L	0.05 mg/l	1/31/2024	E200.8 IC-MS
Nickel Total	0.0012 mg/L	.1 mg/l	1/31/2024	E200.8 IC-MS

Turbidity and TOC 2024															
Navarro Mills							Lake Halbert								
NTU				TOC				NTU				TOC			
Month	Average	Highest	% Compliance	Raw TOC	Tap TOC	% Removal	% Compliance	Month	Average	Highest	% Compliance	Raw TOC	Tap TOC	% Removal	% Compliance
Jan	0.09	0.17	100	5.19	3.75	27.7	148	Jan	0.07	0.14	100	6.21	4.56	26.6	100
Feb	0.10	0.20	100	5.62	3.82	32.0	171	Feb	0.05	0.11	100	5.84	4.34	25.7	100
Mar	0.08	0.15	100	5.63	4.01	28.8	115	Mar	0.05	0.09	100	5.10	3.69	27.6	100
Apr	0.07	0.11	100	5.20	3.45	33.7	135	Apr	0.05	0.12	100	5.01	3.45	31.1	100
May	0.08	0.17	100	4.68	3.09	34.0	136	May	0.05	0.10	100	4.22	2.91	31.0	129
Jun	0.08	0.20	100	5.67	3.43	39.5	158	Jun	0.05	0.10	100	4.74	3.19	32.7	136
Jul	0.07	0.14	100	5.30	3.41	35.7	143	Jul	0.05	0.08	100	5.34	3.40	36.3	104
Aug	0.06	0.11	100	4.81	3.28	31.8	127	Aug	0.05	0.11	100	4.94	3.17	35.8	102
Sep	0.06	0.11	100	4.56	3.37	26.1	104	Sep	0.04	0.08	100	4.57	2.86	37.4	107
Oct	0.06	0.10	100	4.29	2.92	31.9	91	Oct	0.08	0.14	100	5.61	3.80	32.3	100
Nov	0.05	0.08	100	4.71	3.37	28.5	104	Nov	0.08	0.14	100	6.54	4.11	37.2	106
Dec	0.06	0.11	100	5.10	3.48	31.8	116	Dec	0.10	0.18	100	7.25	4.72	34.9	100
Average	0.07			5.06	3.45	31.8	129.0		0.06			5.45	3.68	32.4	107.0
Average Both Plants				NTU	Raw TOC	Tap TOC	% Removal	TOC % compliance is based on compliance with the TCEQ rules on TOC removal. Plants must meet or exceed 100% compliance based on a running quarterly average.							
Average Both Plants				0.07	5.26	3.57	32.1								

TTHM's 2024

Date of Samples	1/31/2024	4/8/2024	8/12/2024		
Address of Sample	1st Quarter	2nd Quarter	3rd Quarter	4th Quarter	Average of Quarters
4501 E HWY 31	39.1	40.7	60.8	38.9	44.9
2117 W 15th Ave	40.9	48.5	80.8	51.7	55.5
3500 Northpark	41.6	46.3	79.4	41.3	52.2
700 E 16th Ave	40.0	46.6	72.5	47.4	51.6
Average for each quarter	40.4	45.5	73.4	44.8	51.0

Haa5's 2024

Date of Samples	1/31/2024	4/8/2024	8/12/2024		
Address of Sample	1st Quarter	2nd Quarter	3rd Quarter	4th Quarter	Average of Quarters
4501 E HWY 31	17.2	18.0	28.5	20.9	21.2
2117 W 15th Ave	15.5	23.3	36.1	16.4	22.8
3500 Northpark	16.9	22.3	43.3	24.5	26.8
700 E 16th Ave	14.0	21.5	44.0	6.90	21.6
Average for each quarter	15.9	21.3	38.0	17.18	23.1

4/2/24, 3:44 PM



TEXAS COMMISSION ON
ENVIRONMENTAL QUALITY

Lab/PWS Electronic Reporting

Home

Water System

My Account

Hello, EROE

Information:

The record has been saved
successfully.

Water System

Create New Reports

Upload SWMOR Reports

Retrieve Saved Reports

View Submission

Enter your quarterly disinfection information in the fields below. Click on "Validate" to check your data and to calculate the quarter average and monthly percentages. Click the "Submit" button when you are ready to transmit your data.

Disinfectant Level Quarterly Operation Report Form

Water System Name: CITY OF DAWSON

PWS ID: TX1750003

Quarter: * 1st - Jan/Feb/Mar

Year: * 2024

Report Form ID: 140286

Type of Disinfectant Used in Distribution System*: * Chloramines (Total

* If you used chloramines and free chlorine at any time during this quarter, select both.

First Month of Quarter: Monthly Summary

Month: January

Was the PWS active this month? ☒

Average of all disinfectant residuals for this month*	Number of residuals collected this month*	Number below MIN for this month*	Number with NO residual for this month*
3.41 mg/L	31 readings	0 readings .0 %	0 readings .0 %

Second Month of Quarter: Monthly Summary

Month: February

Was the PWS active this month? ☒

Average of all disinfectant residuals for this month*	Number of residuals collected this month*	Number below MIN for this month*	Number with NO residual for this month*
2.85 mg/L	29 readings	0 readings .0 %	0 readings .0 %

Third Month of Quarter: Monthly Summary

Month: March

Was the PWS active this month? ☒

Average of all disinfectant residuals for this month*	Number of residuals collected this month*	Number below MIN for this month*	Number with NO residual for this month*
2.81 mg/L	31 readings	0 readings .0 %	0 readings .0 %

Quarterly Summary and Certification

Average of all disinfectant residuals for this quarter	Lowest residual for this quarter*	Highest residual for this quarter*
3.02 mg/L	1.8 mg/L	3.9 mg/L

3/24, 2:03 PM



TEXAS COMMISSION ON
ENVIRONMENTAL QUALITY

Lab/PWS Electronic Reporting

Home Water System My Account

Hello, ER05

Information:

The record has been saved successfully.

Water System

Enter your quarterly disinfection information in the fields below. Click on "Validate" to check your data and to calculate the quarterly average and monthly percentages. Click the "Submit" button when you are ready to transmit your data.

- Create New Reports
- Upload SWMOR Reports
- Retrieve Saved Reports
- View Submission

Disinfectant Level Quarterly Operation Report Form

Water System Name: CITY OF DAWSON

PWS ID: TX1750003

Quarter: * 2nd - Apr/May/Jun

Year: * 2024

Report Form ID: 145558

Type of Disinfectant Used in Distribution System*: * Chloramines (Total

* If you used chloramines and free chlorine at any time during this quarter, select both.

First Month of Quarter: Monthly Summary

Month: April

Was the PWS active this month? ☒

Average of all
disinfectant
residuals for this
month*

Number of
residuals
collected this
month*

Number below
MIN for this
month*

Number with NO
residual for this
month*

3.01
mg/L

30
readings

0
readings .0 %

0
readings .0 %

Second Month of Quarter: Monthly Summary

Month: May

Was the PWS active this month? ☒

Average of all
disinfectant
residuals for this
month*

Number of
residuals
collected this
month*

Number below
MIN for this
month*

Number with NO
residual for this
month*

2.79
mg/L

31
readings

0
readings .0 %

0
readings .0 %

Third Month of Quarter: Monthly Summary

Month: June

Was the PWS active this month? ☒

Average of all
disinfectant
residuals for this
month*

Number of
residuals
collected this
month*

Number below
MIN for this
month*

Number with NO
residual for this
month*

2.78
mg/L

30
readings

0
readings .0 %

0
readings .0 %

Quarterly Summary and Certification

Average of all disinfectant
residuals for this quarter

Lowest residual for
this quarter*

Highest residual for
this quarter*

2.86 mg/L

2.1 mg/L

4 mg/L



Home

Water System

My Account

Hello, ER057365

? Help

STEERS Home

Logout

Water System

Create New Reports

Upload SWMOR Reports

Retrieve Saved Reports

View Submission

Enter your quarterly disinfection information in the fields below. Click on "Validate" to check your data and to calculate the quarterly average and monthly percentages. Click the "Submit" button when you are ready to transmit your data.

Disinfectant Level Quarterly Operation Report Form

Water System Name: CITY OF DAWSON

PWS ID: TX1750003

Quarter: * 3rd - Jul/Aug/Sep

Year: * 2024

Report Form ID: 149934

Type of Disinfectant Used in Distribution System*: * Chloramines (Total -
* If you used chloramines and free chlorine at any time during this quarter, select both.

First Month of Quarter: Monthly Summary

Month: July

Was the PWS active this month? ☒

Average of all
disinfectant
residuals for this
month*

Number of
residuals
collected this
month*

Number below
MIN for this
month*

Number with NO
residual for this
month*

2.67
mg/L

31
readings

0
readings .0 %

0
readings .0 %

Second Month of Quarter: Monthly Summary

Month: August

Was the PWS active this month? ☒

Average of all
disinfectant
residuals for this
month*

Number of
residuals
collected this
month*

Number below
MIN for this
month*

Number with NO
residual for this
month*

2.74
mg/L

31
readings

0
readings .0 %

0
readings .0 %

Third Month of Quarter: Monthly Summary

Month: September

Was the PWS active this month? ☒

Average of all
disinfectant
residuals for this
month*

Number of
residuals
collected this
month*

Number below
MIN for this
month*

Number with NO
residual for this
month*

2.8
mg/L

30
readings

0
readings .0 %

0
readings .0 %

Quarterly Summary and Certification

Average of all disinfectant
residuals for this quarter

Lowest residual for
this quarter*

Highest residual for
this quarter*

2.74 mg/L

2.4 mg/L

3 mg/L



Water System

Create New Reports
Upload SWMOR Reports
Retrieve Saved Reports
View Submission

Enter your quarterly disinfection information in the fields below. Click on "Validate" to check your data and to calculate the quarterly average and monthly percentages. Click the "Submit" button when you are ready to transmit your data.

Disinfectant Level Quarterly Operation Report Form

Water System Name: CITY OF DAWSON

PWS ID: TX1750003

Quarter: * 4th - Oct/Nov/Dec

Year: * 2024

Report Form ID: 156022

Type of Disinfectant Used in Distribution System*: * Chloramines (Total

* If you used chloramines and free chlorine at any time during this quarter, select both.

First Month of Quarter: Monthly Summary

Month: October

Was the PWS active this month? ☒

Average of all disinfectant residuals for this month*	Number of residuals collected this month*	Number below MIN for this month*	Number with NO residual for this month*
2.67 mg/L	31 readings	0 readings .0 %	0 readings .0 %

Second Month of Quarter: Monthly Summary

Month: November

Was the PWS active this month? ☒

Average of all disinfectant residuals for this month*	Number of residuals collected this month*	Number below MIN for this month*	Number with NO residual for this month*
2.75 mg/L	30 readings	0 readings .0 %	0 readings .0 %

Third Month of Quarter: Monthly Summary

Month: December

Was the PWS active this month? ☒

Average of all disinfectant residuals for this month*	Number of residuals collected this month*	Number below MIN for this month*	Number with NO residual for this month*
2.83 mg/L	31 readings	0 readings .0 %	0 readings .0 %

Quarterly Summary and Certification

Average of all disinfectant residuals for this quarter	Lowest residual for this quarter*	Highest residual for this quarter*
2.75 mg/L	2.4 mg/L	3.1 mg/L